

IEEE Guide for Liquid-Immersed Transformers Through-Fault- Current Duration

IEEE Power and Energy Society

Sponsored by the
Transformers Committee

IEEE
3 Park Avenue
New York, NY 10016-5997
USA

IEEE Std C57.109™-2018
(Revision of IEEE Std C57.109-1993)

This is a preview. [Click here to purchase the full publication.](#)

IEEE Guide for Liquid-Immersed Transformers Through-Fault- Current Duration

Sponsor

Transformers Committee
of the
IEEE Power and Energy Society

Approved 27 September 2018

IEEE-SA Standards Board

Abstract: Recommendations believed essential for the application of overcurrent protective devices applied to limit the exposure time of transformers to short circuit current are set forth. Transformer coordination curves are presented for four categories of transformers. There is no intent to imply overload capability.

Keywords: IEEE C57.109™, liquid-immersed transformer, transformer

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2018 by The Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 5 October 2018. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-1-5044-5138-3 STD23279
Print: ISBN 978-1-5044-5139-0 STDPD23279

IEEE prohibits discrimination, harassment, and bullying.

For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

This is a preview. [Click here to purchase the full publication.](#)