

ANSI/NEMA WC 74/ICEA S-93-639-2017

5-46 kV Shielded Power Cable for Use in the Transmission and Distribution of Electric Energy





Approved as an American National Standard
ANSI Approval Date: December 6, 2017

ANSI/NEMA WC 74/ICEA S-93-639-2017

*5-46 kV Shielded Power Cable for Use in the Transmission and Distribution of
Electric Energy*

Prepared by:

Insulated Cable Engineers Association, Inc.

www.icea.net

Published by:

National Electrical Manufacturers Association

1300 North 17th Street, Suite 900
Arlington, Virginia 22209

www.nema.org

© 2017 National Electrical Manufacturers Association and the Insulated Cable Engineers Association, Inc.
All rights including translation into other languages, reserved under the Universal Copyright Convention,
the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan
American Copyright Conventions.

This is a preview. [Click here to purchase the full publication.](#)

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) and the Insulated Cable Engineers Association (ICEA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together persons who have an interest in the topic covered by this publication. While NEMA and ICEA administers the process and establishes rules to promote fairness in the development of consensus, they do not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA and ICEA disclaims liability for personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA and ICEA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA and ICEA do not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA and ICEA are not undertaking to render professional or other services for or on behalf of any person or entity, nor are NEMA and ICEA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA and ICEA have no power, nor do they undertake to police or enforce compliance with the contents of this document. NEMA and ICEA do not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and ICEA and is solely the responsibility of the certifier or maker of the statement.

Foreword

This standards publication, *5-46 kV Shielded Power Cable for Use in the Transmission and Distribution of Electric Energy*, was developed by the Insulated Cable Engineers Association, Inc. (ICEA) and approved by the National Electrical Manufacturers Association (NEMA).

ICEA/NEMA standards are adopted in the public interest and are designed to eliminate misunderstanding between the manufacturer and the user and to assist the user in selecting and obtaining the proper product for his particular need. Existence of an ICEA/NEMA standard does not in any respect preclude the manufacture or use of products not conforming to the standard. The user of this standard is cautioned to observe any health or safety regulations and rules relative to the manufacture and use of cable made in conformity with this standard.

Requests for interpretation of this standard must be submitted in writing to:

Insulated Cable Engineers Association, Inc.
www.icea.net

An official interpretation will be provided. Suggestions for improvements gained in the use of this standard will be welcomed by the association.

The members of the ICEA working group contributing to the writing of this Standard consisted of the following:

W. A. Crawford, Chairman

J. Armstrong
R. Bristol
J. Fino
F. Kuchta
B. Miller
K. Porter
R. Szilagyi
S. Wetzel

E. Bartolucci
J. Cancelosi
R. Fleming
P-M. Leblanc
J. Mumm
H. Soleski
J. Weitzel

M. Bodziony
A. Davila
K. Knuckles
J. Maximo
R. Murphy
C. Spradlin
T. West

Suggestions for improvement of this standard are welcome. They should be sent to:

National Electrical Manufacturers Association,
1300 North 17th Street, Suite 900,
Rosslyn, VA 22209
Attention: Secretary ANSI ASC C8
khaled.masri@nema.org

This standard was processed and approved by the Power Control & Instrumentation (PCI) Wire & Cable Subcommittee of the Accredited Standards Committee C8. Subcommittee approval does not necessarily imply that all Subcommittee members voted for its approval. At the time it approved this standard, the C8 PCI Subcommittee had the following members:

Gerald Dorna, Chairman, Belden
Khaled Masri, Secretary, NEMA

Name of Representative		Organization
Gerald	Dorna	Belden
Christel	Hunter	Cerro Wire LLC
Samuel	Friedman	General Cable
Nigel	Hampton	NEETRAC
Lauri	Hiivala	Power Cable Consultant
Dave	Mercier	Southwire Company
Susan	Stene	UL LLC
Trung	Hiu	USDA Rural Development Utilities Programs

CONTENTS

Section 1 General	1
1.1 SCOPE	1
1.2 GENERAL INFORMATION	1
1.3 INFORMATION TO BE SUPPLIED BY PURCHASER	1
1.3.1 Characteristics of Systems on Which Cable is to be Used	1
1.3.2 Quantities and Description of Cable	2
1.4 DEFINITIONS AND SYMBOLS	2
Section 2 Conductor	6
2.1 PHYSICAL AND ELECTRICAL PROPERTIES	6
2.1.1 Copper Conductors	6
2.1.2 Aluminum Conductors	6
2.2 OPTIONAL WATER BLOCKING COMPONENTS FOR STRANDED CONDUCTORS	7
2.3 CONDUCTOR SIZE UNITS	7
2.4 CONDUCTOR DC RESISTANCE PER UNIT LENGTH	7
2.4.1 Direct Measurement of DC Resistance	7
2.4.2 Calculation of DC Resistance Per Unit Length	7
2.5 CONDUCTOR DIAMETER	8
Section 3 Conductor Shield (Stress Control Layer)	14
3.1 MATERIAL	14
3.2 PHYSICAL REQUIREMENTS	14
3.3 ELECTRICAL REQUIREMENTS	14
3.3.1 Extruded Semiconducting Material	14
3.3.2 Extruded Nonconducting Material (For EPR Insulation Only)	14
3.3.2.1 Withstand Test	14
3.3.2.2 Electrical Requirements	15
3.3.3 Semiconducting Tape	15
3.4 CROSSLINKED (THERMOSET) REQUIREMENTS	15
Section 4 Insulation	16
4.1 MATERIAL	16
4.2 INSULATION THICKNESS	17
4.2.1 Selection of Proper Thickness	17
4.2.1.1 For Three-Phase Systems with 100, 133 or 173 Percent Insulation Level	17
4.2.1.2 For Delta Systems Where One Phase May Be Grounded For Periods Over One Hour	17
4.2.1.3 For Single- and Two-Phase Systems with 100 Percent Insulation Level	17
4.2.1.4 For Single- and Two-Phase Systems with 133 Percent Insulation Level	17
4.3 INSULATION REQUIREMENTS	17
4.3.1 Physical and Aging Requirements	17
4.3.2 Electrical Requirements	18
4.3.2.1 Partial-Discharge Extinction Level for Discharge-Free Designs Only	18
4.3.2.2 Discharge (Corona) Resistance for Discharge-Resistant Designs Only	19
4.3.2.3 Voltage Tests	19
4.3.2.4 Accelerated Water Absorption Test	19
4.3.2.5 Insulation Resistance	19
Section 5 Insulation Shielding	23
5.1 SHIELDING OF INSULATED CABLE	23
5.1.1 Insulation Shield	23

5.1.1.1	Nonmetallic Covering	23
5.1.1.2	Thickness Requirements.....	23
5.1.1.3	Degree of Crosslinking (Extruded Thermoset Insulation Shield only).....	24
5.2	REMOVABILITY OF INSULATION SHIELD	24
5.2.1	Discharge-Free Cable Designs with Extruded Insulation Shields.....	24
5.2.2	Discharge-Resistant Cable Designs with Extruded Insulation Shields	24
Section 6 Metallic Shielding (See Appendix G).....		27
6.1	GENERAL.....	27
6.2	METAL TAPES	27
6.2.1	Helically Applied Tape(s).....	27
6.2.2	Longitudinally Applied Corrugated Tape	27
6.3	COPPER WIRES, STRAPS, SHEATH OR ARMOR.....	27
6.4	MULTIPLE-CONDUCTOR CABLES	28
Section 7 Coverings.....		29
7.1	JACKETS.....	29
7.1.1	Crosslinked and Thermoplastic Jackets - General.....	29
7.1.2	Neoprene, Heavy-Duty Black (CR-HD).....	29
7.1.3	Neoprene, General Purpose (CR-GP)	29
7.1.4	Polyvinyl Chloride (PVC)	29
7.1.5	Low and Linear Low Density Polyethylene (LDPE & LLDPE).....	29
7.1.6	Medium Density Polyethylene, Black (MDPE)	29
7.1.7	High Density Polyethylene (HDPE).....	29
7.1.8	Nitrile-butadiene/Polyvinyl-chloride, Heavy-Duty (NBR/PVC-HD)	30
7.1.9	Nitrile-butadiene/Polyvinyl-chloride, General – Purpose Duty (NBR/PVC-GP)	30
7.1.10	Chlorosulfonated Polyethylene, Heavy Duty (CSPE-HD)	30
7.1.11	Chlorinated Polyethylene, Thermoplastic (CPE-TP)	30
7.1.12	Chlorinated Polyethylene, Crosslinked, Heavy Duty (CPE-XL-HD).....	30
7.1.13	Polypropylene (PP)	30
7.1.14	Thermoplastic Elastomer (TPE)	30
7.1.15	Low Smoke Halogen Free Jackets (LSHF)	30
7.1.16	Repairs	30
7.1.17	Test for Suitability for Exposure to Sunlight	31
7.1.18	Optional Tray Cable Flame Test Requirement.....	31
7.1.19	Separator Under Jacket	31
7.1.20	Jacket Thickness.....	34
7.1.21	Jacket Irregularity Inspection.....	34
7.2	METALLIC AND ASSOCIATED COVERINGS.....	35
7.2.1	General.....	35
7.2.1.1	Divisions	36
7.3	DIVISION I	36
7.3.1	Metallic Sheaths	36
7.3.1.1	Lead Sheaths	36
7.3.1.2	Aluminum Sheaths	38
7.3.2	Flat Steel Tape Armor	38
7.3.2.1	Tensile Strength and Elongation	38
7.3.2.2	Galvanizing (Zinc Coating) Test.....	39
7.3.2.3	Tape Size	39
7.3.2.4	Application, Lay, and Spacing of Tapes.....	40
7.3.3	Interlocked Metal Tape Armor	40
7.3.3.1	Steel Tape	40
7.3.3.2	Non-magnetic Tape	41
7.3.3.3	Flexibility Test for Interlocked Metal Tape.....	41
7.3.4	Continuously Corrugated Metal Armor.....	41

7.3.4.1	Type of Metal.....	41
7.3.4.2	Thickness	42
7.3.4.3	Flexibility	42
7.3.5	Galvanized Steel Wire Armor for Submarine Cables	42
7.3.5.1	Physical Requirements.....	42
7.3.5.2	Galvanizing (Zinc Coating) Tests	43
7.3.5.3	Size of Armor Wire	44
7.3.5.4	Lay	44
7.3.6	Bedding Over Cable Cores To Be Metallic Armored.....	44
7.3.6.1	Unsheathed or Unjacketed Cores	44
7.3.6.2	Jacketed Cores or Sheathed Non-jacketed Cores.....	45
7.3.7	Outer Servings.....	45
7.3.7.1	Over Metallic Sheath (Without Armor or Jacket).....	45
7.3.7.2	Over Metallic Armored Cables	46
7.3.8	Crosslinked Jackets Over Metallic Sheaths and Armors	46
7.3.9	Thermoplastic Jackets Over Metallic Sheaths or Armors	46
7.4	DIVISION II	47
7.4.1	Borehole Cable (Suspended at One End Only)	48
7.4.1.1	Armor	48
7.4.1.2	Wire Band Serving	48
7.4.2	Dredge Cable	48
7.4.2.1	Armor	48
7.4.3	Shaft Cable.....	49
7.4.3.1	Tape or Wire Armor For Clamped Cables.....	49
7.4.3.2	Wire Armor For Vertically Suspended Cables.....	49
7.4.4	Vertical Riser Cable.....	50
7.4.4.1	Armor	50
7.4.4.2	Size of Armor Wire	50
7.5	DIVISION III	50
7.5.1	Buried Land Cables	50
7.5.1.1	Armor	50
Section 8 Assembly, Fillers, and Cable Identification.....		52
8.1	ASSEMBLY OF MULTIPLE-CONDUCTOR CABLES.....	52
8.1.1	With a Common Covering	52
8.1.2	Without a Common Covering	52
8.2	FILLERS	53
8.3	CONDUCTOR IDENTIFICATION.....	53
8.3.1	Grounding Conductors	53
8.4	CABLE IDENTIFICATION	53
Section 9 Production Tests and Test Methods		55
9.1	GENERAL.....	55
9.1.1	Testing and Test Frequency.....	55
9.1.2	Test Methods.....	55
9.1.3	Number of Test Specimens from Samples	58
9.2	THICKNESS MEASUREMENTS.....	58
9.2.1	Beddings and Servings	58
9.2.2	Other Components	58
9.3	SAMPLES AND SPECIMENS FOR PHYSICAL AND AGING TESTS	58
9.3.1	General.....	58
9.3.2	Sampling.....	58
9.3.2.1	Extrudable Conductor Stress Control Material.....	58
9.3.2.2	Insulations	58
9.3.2.3	Thermoplastic Jackets.....	58

9.3.2.4	Crosslinked Jackets	58
9.3.3	Size of Test Specimens.....	59
9.3.4	Specimens with Bonded Layers.....	59
9.3.5	Specimen Surface Irregularities	59
9.3.6	Specimens for the Aging Tests	59
9.3.7	Calculation of Area of Test Specimens	60
9.3.7.1	Annular Specimens	60
9.3.7.2	Thin Sections That Are Arcs of Annuli	60
9.3.7.3	Thick Specimens That Are Arcs of Annuli.....	60
9.3.7.4	Specimens That Are Segments of Circles	60
9.3.7.5	Irregular Specimens	61
9.4	AGING TESTS.....	61
9.4.1	Air Oven Aging Test	61
9.4.2	Oil Immersion Test	61
9.5	HEAT SHOCK TEST	61
9.6	COLD-BEND TEST.....	62
9.7	TIGHTNESS OF POLYETHYLENE JACKET TO SHEATH TEST.....	62
9.8	ELECTRICAL TESTS ON COMPLETED CABLES.....	62
9.8.1	Voltage Tests.....	62
9.8.1.1	General.....	62
9.8.1.2	Cables With Metallic Sheath, Metallic Shield, or Metallic Armor.....	62
9.8.1.3	AC Voltage Test	62
9.8.2	Partial-Discharge Test Procedure	63
9.9	ADHESION (INSULATION SHIELD REMOVABILITY TEST)	63
9.10	HOT CREEP TEST.....	63
9.11	SOLVENT EXTRACTION.....	63
9.12	WAFER BOIL TEST FOR EXTRUDED THERMOSET SHIELDS.....	63
9.12.1	Insulation Shield Hot Creep Properties	63
9.13	WATER CONTENT.....	63
9.13.1	Water Under the Jacket.....	63
9.13.2	Water in the Conductor	64
9.13.3	Water Expulsion Procedure.....	64
9.13.4	Presence of Water Test.....	64
9.14	VOLUME RESISTIVITY.....	64
9.15	RETESTS	64
9.15.1	Physical and Aging Properties and Thickness	64
9.15.2	Other Tests.....	65
9.16	CONDUCTOR TEST METHODS	65
9.16.1	Method for DC Resistance Determination.....	65
9.16.2	Retests for DC Resistance	65
Section 10	Qualification Tests	66
10.1	ACCELERATED WATER ABSORPTION TEST	66
10.2	INSULATION RESISTANCE TEST	66
10.3	DRY ELECTRICAL TEST FOR CLASS III INSULATIONS ONLY	67
10.3.1	Test Samples.....	67
10.3.2	Test Procedure	67
10.3.3	Electrical Measurements	67
10.4	TEST FOR DISCHARGE RESISTANT INSULATION (EPR CLASS IV INSULATION ONLY) ..	67
10.5	BRITTLINESS TEST FOR SEMICONDUCTING SHIELDS.....	68
10.5.1	Test Samples.....	68
10.5.2	Test Procedure	68
10.6	TRAY CABLE FLAME TEST	68
10.7	SUNLIGHT RESISTANCE TEST	68
10.8	DIELECTRIC CONSTANT AND DISSIPATION FACTOR	68

10.9	HALOGEN CONTENT OF NON-METALLIC ELEMENTS	69
10.10	SMOKE GENERATION TEST	69
10.11	ACID GAS EQUIVALENT TEST	69
10.12	ENVIRONMENTAL STRESS CRACKING TEST	69
10.13	ABSORPTION COEFFICIENT	69
10.14	DIELECTRIC CONSTANT AND VOLTAGE WITHSTAND FOR NONCONDUCTING STRESS CONTROL LAYERS	69
Section 11	Constructions of Specific Cable Types	70
11.1	PREASSEMBLED AERIAL CABLE	70
11.1.1	Scope	70
11.1.2	Conductors	70
11.1.2.1	Copper	70
11.1.2.2	Aluminum	70
11.1.2.3	Conductor Stress Control Layer	70
11.1.3	Insulation	70
11.1.4	Cable Types	70
11.1.4.1	Type I – Shielded, Nonjacketed	70
11.1.4.2	Type II – Shielded, Jacketed	70
11.1.5	Jacket	70
11.1.6	Identification	71
11.1.7	Assembly	71
11.1.8	Messenger	71
11.1.9	Design Criteria	71
11.1.10	Tests	72
APPENDIX A	Industry Standard References (Normative)*	74
APPENDIX B	Emergency Overloads (Normative)	78
APPENDIX C	Procedure for Determining Dimensional Requirements of Jackets and Associated Coverings (Normative)	79
APPENDIX D	Optional Factory DC Test (Informative)	82
APPENDIX E	Representative Tensile Strength And Elongation Of Nonmagnetic Metals (Informative)	83
APPENDIX F	Voltage Tests During and After Installation (Informative)	84
APPENDIX G	Shielding (Informative)	86
APPENDIX H	Additional Conductor Information (Informative)	88
APPENDIX I	Recommended Bending Radii For Cables (Informative)	91
APPENDIX J	Ethylene Alkene Copolymer (EAM) (Informative)	94
APPENDIX K	Cable Qualification for Submerged Applications (Informative)	95