1

UL 248-17

Outline of Investigation for Low-Voltage Fuses – Part 17: Class CF Fuses

Summary of Topics

This fifth issue of the Outline of Investigation for Low-Voltage Fuses – Part 17: Class CF Fuses, UL 248-17, covers Class CF fuses rated 400A or less and 600V. Revisions include corrections to fuse dimensions from 101 – 225A and addition of a 200A fuse configuration.

UL's Outlines of Investigation are copyrighted by UL LLC. Neither a printed nor electronic copy of an Outline of Investigation should be altered in any way. All of UL's Outlines of Investigation and all copyrights, ownerships, and rights regarding those Outlines of Investigation shall remain the sole and exclusive property of UL LLC.

COPYRIGHT © 2018 UL LLC

No Text on This Page

CONTENTS

1	General		5
		Scope	
4	Classif	ication	5
5 Characteristics			
-		Voltage rating	
	5.3	Current rating	
		Interrupting rating	
	5.6	Peak let-through current and clearing I ² t characteristics	ŗ
7	Construction		
		Dimensions	
8			
		Verification of temperature rise and current-carrying capacity	
		Verification of overload operation	
		Verification of operation at rated voltage	
		Verification of peak let-through current and clearing l ² t characteristics	